Student Services

Oakland District Office
1515 Clay Street, Suite 1301
Oakland, CA 94612
Phone: 510.622.3026
Fax: 510.622.3045

May 26, 2023

STATE OF CALIFORNIA
DEPARTMENT OF INDUSTRIAL RELATIONS
DIVISION OF OCCUPATIONAL SAFETY AND HEALTH

PRELIMINARY ORDER

PERALTA COMMUNITY COLLEGE DISTRICT
DIR OF FAC
333 E 8TH ST
OAKLAND, CA 94606-2844

NOTE: Pay invoice EI968451OA within 60 days from its issuance to avoid a 100% penalty assessment. All fees are due IMMEDIATELY upon receipt of the invoice.

A survey of your Passenger, Hydroelectric, EV 5, State Number 051537 located at 900 Fallon St, Oakland was made on May 16, 2023 by EU Engineer, T. Fernandez. Person Contacted FERNANDO Compliance date July 17, 2023.

The conditions in need of correction are noted below. The numbers following the listed items refer to the sections of the California Code of Regulations (Title 8), or the Labor Code (L.C.) of the State of California

1. The emergency battery lowering device shall be tested for proper operation under all six (6) conditions listed in Circular Letter E-01-03. California Labor Code subsection 7318 ; [Ref. Circular Letter E-01-03]

2. The elevator pit lighting shall be made operative and shall provide an illumination of not less than 5 foot-candles measured at the pit floor next to the access ladder or door. subsection 3016(f) , 3053 [CEC 620]

3. The machine room floor shall be kept clean and free from oil, grease, water, and dirt. subsection 3000(h) , 3050(b)(4)

Notification in writing that each of the listed items have been complied with shall be submitted to the above listed District office on the Compliance Form available at www.dir.ca.gov/dosh/ElevatorPubs_forms.html before the PERMIT TO OPERATE will be issued. Failure to Notify the Division within the allotted time may result in additional Penalties being assessed.

NO PERMIT WILL BE ISSUED UNTIL NOTIFICATION HAS BEEN RECEIVED AND ALL FEES ARE PAID.

Dave Henderson, Senior Safety Engineer

Af

Department of Service Services
Peralta Community College District

JUN 07 2023

#3 water is comming thrue the wall from a bathroom floor above the machine room